



Sloped roof



Double door with Louvered vent



TITLE  
**PWH3636**

DRAWN BY  
J. Ellison

DATE  
17/12/2021

Foundation Requirements:  
The foundation area must be no less in length and width than the external dimensions of the enclosure. The foundation must be constructed so as to be capable of supporting the weight of the enclosure and equipment contained within it. The foundation must be continuous and be no more than ±2mm over any given metre.

DESCRIPTION:  
PWH3636 c/w Louvered vent

DATE	VERSION	NOTES
17/12/2021	A	FIRST ISSUE

TANK SPECIFICATION :	
INTERNAL DIMENSIONS	2440 x 1220 x 1220mm
EXTERNAL DIMENSIONS	2590 x 1370 x 1300mm
NOM. CAPACITY	3636 Litres
DRY WEIGHT	220 KG
INSULATION THICKNESS	25mm
MATERIAL	GRP




CUSTOMER  
CUSTOMER


ALL DIMENSIONS +/- 5mm UNLESS OTHERWISE STATED

A4

ALL DIMENSIONS IN MM DO NOT SCALE

SCALE:1:30 SHEET 1 OF 2





TITLE  
**PWH3636 Green**

DRAWN BY  
**J. Ellison**

DATE  
**17/12/2021**

CUSTOMER  
**CUSTOMER**

Foundation Requirements:  
 The foundation area must be no less in length and width than the external dimensions of the enclosure. The foundation must be constructed so as to be capable of supporting the weight of the enclosure and equipment contained within it. The foundation must be continuous and be no more than ±2mm over any given metre.

ALL DIMENSIONS +/- 5mm  
 UNLESS OTHERWISE STATED

DESCRIPTION:  
**PWH3636 c/w Louvered vent, Green**

A4

ALL DIMENSIONS IN MM    DO NOT SCALE

DATE	VERSION	NOTES
17/12/2021	A	FIRST ISSUE

**TANK SPECIFICATION :**

INTERNAL DIMENSIONS	2440 x 1220 x 1220mm
EXTERNAL DIMENSIONS	2590 x 1370 x 1300mm
NOM. CAPACITY	3636 Litres
DRY WEIGHT	220 KG
INSULATION THICKNESS	25mm
MATERIAL	GRP



SCALE:1:30    SHEET 2 OF 2