



TITLE		<small>NOTE:</small> Tanks Direct sectional tanks must be fully supported on a flat, level & continuous foundation which provides structural support to the tank when full to a maximum capacity. It is essential that the installer and/or user refers to the conditions of the installation document prior to the installation of the tank. Under no circumstances should any part of the tank structure be used to provide support to pipework and/or any ancillary items.
PW.1.5x1x2.IFB.AB		
DRAWN BY	DATE	
J. Ellison	03/02/2022	
CUSTOMER		
CUSTOMER		

DESCRIPTION:	
PW.1.5x1x2.IFB.AB Sectional cold water storage tank c/w raised float valve housing to provide an AB Air gap	
ALL DIMENSIONS +/- 5mm UNLESS OTHERWISE STATED	

DATE		VERSION	NOTES
21/06/2021		A	FIRST ISSUE

TANK SPECIFICATION :	
INTERNAL DIMENSIONS	1500 x 1000 x 2000mm
EXTERNAL DIMENSIONS	1640 x 1417 x 2567mm
NOM. CAPACITY	3000 Litres
INSULATION THICKNESS	25mm
MATERIAL	Hot press moulded GRP



SCALE:1:30

SHEET 1 OF 1