



TITLE		NOTE: Tanks Direct sectional tanks must be fully supported on a flat, level & continuous foundation which provides structural support to the tank when full to a maximum capacity. It is essential that the installer and/or user refers to the conditions of the installation document prior to the installation of the tank. Under no circumstances should any part of the tank structure be used to provide support to pipework and/or any ancillary items.	DESCRIPTION: PW.2x1x2.IFB.DIV.AG Sectional cold water storage tank c/w access manways to provide an AG Air gap	DATE	VERSION	NOTES
PW.2x1x2.IFB.DIV.AG				18/05/2021	A	FIRST ISSUE
DRAWN BY	J. Ellison	DATE	07/02/2022			
CUSTOMER	CUSTOMER					

ALL DIMENSIONS +/- 5mm UNLESS OTHERWISE STATED	A4
--	----

ALL DIMENSIONS IN MM - DO NOT SCALE
-------------------------------------

INTERNAL DIMENSIONS	2000 x 1000 x 2000mm
EXTERNAL DIMENSIONS	2140 x 1140 x 2201mm
NOM. CAPACITY	4000 Litres
INSULATION THICKNESS	25mm
MATERIAL	Hot press moulded GRP

TANK SPECIFICATION :	
INTERNAL DIMENSIONS	2000 x 1000 x 2000mm
EXTERNAL DIMENSIONS	2140 x 1140 x 2201mm
NOM. CAPACITY	4000 Litres
INSULATION THICKNESS	25mm
MATERIAL	Hot press moulded GRP

	SCALE:1:35	SHEET 1 OF 1
--	------------	--------------