



TITLE
PW4001.INS-2 (AG)

DRAWN BY
 J. Ellison

DATE
 06/04/2022

CUSTOMER
 CUSTOMER

NOTE:
 All Tanks Direct tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.

ALL DIMENSIONS +/- 5mm
 UNLESS OTHERWISE STATED

DESCRIPTION:
 PW4001-AG Two piece cold water storage tank suitable for AG/AF Air gaps

A4

ALL DIMENSIONS IN MM - DO NOT SCALE

| DATE | VERSION | NOTES |
|------------|---------|-------------|
| 15/12/2021 | A | FIRST ISSUE |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

TANK SPECIFICATION :

| | |
|----------------------|----------------------|
| INTERNAL DIMENSIONS | 2000 x 1000 x 2000mm |
| EXTERNAL DIMENSIONS | 2202 x 1202 x 2093mm |
| NOM. CAPACITY | 4000 Litres |
| DRY WEIGHT | 300 KG |
| INSULATION THICKNESS | 25mm |
| WRAS CERT. NUMBER | 1310072 |
| MATERIAL | GRP |

SCALE: 1:40

SHEET 1 OF 1