



TITLE
PW1.5x1x1.5.TIF.DIV.AB

DRAWN BY C.MORRIS DATE 31/01/2023

CUSTOMER CUSTOMER

NOTE:
Tanks Direct sectional tanks must be fully supported on a flat, level & continuous foundation which provides structural support to the tank when full to a maximum capacity. It is essential that the installer and/or user refers to the conditions of the installation document prior to the installation of the tank. Under no circumstances should any part of the tank structure be used to provide support to pipework and/or any ancillary items.

ALL DIMENSIONS +/- 5mm
UNLESS OTHERWISE STATED

A4

DESCRIPTION:
PW.2x2x2. Sectional cold water storage tank

ALL DIMENSIONS IN MM - DO NOT SCALE

DATE	VERSION	NOTES
27/01/2023	A	FIRST ISSUE

TANK SPECIFICATION :

INTERNAL DIMENSIONS	xxx
EXTERNAL DIMENSIONS	xxx
NOM. CAPACITY	xxx Litres
INSULATION THICKNESS	25mm
MATERIAL	Hot press moulded GRP



SCALE:1:35

SHEET 1 OF 1