

- Notes:

   Pumpwell delivered with pumps & floats not installed to avoid damage in transit.
- Pumps to be coupled to chains with shackles supplied in lifting chain which is connected to the unistrut assembly.
  Read operating and installation guidelines before installing.

Please check with Kingspan Water & Energy for the latest Issue of the drawing							
Issue	ssue Date Drawn By Approved By Description		Description				
03	16/12/2022	TGY		ECN 1641 - Access Size Added			
02	29/05/2018	WMD		CC1434 - HLA/Assist float position changed			

All Dimensions In mm	Scale: Do Not Scale

A:\Wastewater\Engineering\Drawing Data\02 - Sales Drawings\DS\DS - 10\DS1060P

<b>-</b>
Third Angle Projection
Third Angle Projection

LN Number:	Tolerance (unless stated) :	г
Finish:	Thickness:	L
Weight:	Surface Area: m <sup>2</sup>	С
Modelled By : Author	Material : PE	Г
100	E II	

Kingspan Water & Energy reserve the
right to alter the details of this drawing without prior notice.
This drawing is copyright and may not be reproduced or used without
the written permission of Kingspan Water & Energy

Case Diameter	Outlet Invert 'C'	Case Depth 'B'		Inlet Invert 'A' - Standard		Inlet
		20 (2.0m)	25 (2.5m)	10 (1.0m)	15 (1.5m)	Size 'E'
10 (1.0m)	0.6m	•		•		110mm
			•		•	160mm

Drawing: DS1060P Page 1 of 1

Pump Chamber Ø1.0 Sewage

