



Certificate number: 2305752 (1)

Issued 24/05/2023

Expires 24/05/2028

## Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

### Direct Pumps and Tanks Limited

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

**Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.**

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory  
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

CERTIFICATE

Kiwa Watertec  
(A Trading Division of Kiwa Ltd)  
26A Rassau Industrial Estate  
Ebbw Vale  
Gwent  
NP23 5SD  
United Kingdom  
T +44 (0)1495 308185  
[uk.water@kiwa.com](mailto:uk.water@kiwa.com)  
[www.kiwa.co.uk](http://www.kiwa.co.uk)

**Certificate Issued to:**  
Direct Pumps and Tanks Limited  
Unit 12 Cossall Industrial Estate  
Ilkestone  
Derby  
DE7 5UA  
United Kingdom



KUKreg4

# Product Certificate

Appendix to Certificate number: 2305752

The following products belong to this certificate

<p>PRODUCT DESCRIPTION</p> <p>Range of Vari-RS - Single, Twin &amp; Triple Cold Water Booster Sets incorporating pumps, expansion vessels, Isolation valves and non-return valves (not suitable for backflow protection).</p> <p>ATS3 – Without Production Surveillance.</p>
<p>MODEL(S)</p> <p>1RS302/8DPT</p> <p>1RS305/8DPT</p> <p>1RS306/8DPT</p> <p>1RS307/8DPT</p> <p>1RS308/8DPT</p> <p>1RS502/8DPT</p> <p>1RS505/8DPT</p> <p>1RS506/8DPT</p> <p>1RS507/8DPT</p> <p>1RS508/8DPT</p> <p>1RS1002/8DPT</p> <p>1RS1003/8DPT</p> <p>1RS1004/8DPT</p> <p>1RS1005/8DPT</p> <p>1RS1006/8DPT</p> <p>2RS302/8DPT</p> <p>2RS305/8DPT</p> <p>2RS306/8DPT</p> <p>2RS307/8DPT</p> <p>2RS308/8DPT</p> <p>2RS502/8DPT</p> <p>2RS505/8DPT</p> <p>2RS506/8DPT</p> <p>2RS507/8DPT</p> <p>2RS508/8DPT</p> <p>2RS1002/8DPT</p> <p>2RS1003/8DPT</p> <p>2RS1004/8DPT</p> <p>2RS1005/8DPT</p> <p>2RS1006/8DPT</p> <p>3RS302/8DPT</p> <p>3RS305/8DPT</p> <p>3RS306/8DPT</p> <p>3RS307/8DPT</p> <p>3RS308/8DPT</p> <p>3RS502/8DPT</p> <p>3RS505/8DPT</p> <p>3RS506/8DPT</p> <p>3RS507/8DPT</p> <p>3RS508/8DPT</p> <p>3RS1002/8DPT</p> <p>3RS1003/8DPT</p> <p>3RS1004/8DPT</p> <p>3RS1005/8DPT</p> <p>3RS1006/8DPT</p>
<p>SIZE:</p>

# Product Certificate

Appendix to Certificate number: 2305752

---

1" x 1 1/4" BSP (F). 2" x 3" BSP (M).
<b>SCOPE:</b> Manufacturer recommended maximum working pressure: 1.5 bar, 1.75 bar, 1.8 bar, 2.5 bar, 3.5 bar, 4 bar, 4.5 bar, 5 bar, 5.25 bar, 6.5 bar and 7 bar & maximum operating temperature: Cold water use only. Hygienic Purposes: Non-metallic materials suitable for continuous use with cold water only.
<b>MARKING</b> DPT, Tel No and website on adhesive label on body.
<b>MATERIALS</b> Non-metallic materials assessed (BS6920) to point of discharge.
<b>BACKFLOW PROTECTION NOTES</b> N/A.
<b>ADDITIONAL NOTES</b> All water contact & exposed components satisfy opacity requirements. Notification should be given in writing of the proposed installation of this fitting to the local Water Supplier prior to its installation. The fitting shall not be installed until consent is given by the Water Supplier in line with Regulation 5 of the Water Supply (Water Fittings) Regulations 1999 or the Water Supply (Water Fittings) Regulations (Northern Ireland) 2009, or Byelaw 5 of the Water Supply (Water Fittings) (Scotland) Byelaws 2014.

## Extra Notes