



kiwa

CERTIFICATE

Certificate number: 2601705 (1)

Issued 09/01/2026
Expires 09/01/2031

Kiwa Regulation 4(KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 (issue 7) – Regulation 4(1)(a)
Model number(s) – see Appendix

Kingspan Water & Energy Ltd.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

**Regulation 4(1)(a) of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009
Northern Ireland and 2014 Byelaws Scotland.**

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Replication of this certificate is allowed in its entirety.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en-gb/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:

Kingspan Water & Energy Ltd.
180 Gilford Road
Portadown
BT63 5LE
United Kingdom



Product Certificate



Appendix to Certificate number: 2601705

The following products belong to this certificate

PRODUCT DESCRIPTION Range of one piece plastic potable water storage tanks. ATS3 – Without Production Surveillance.
MODEL(S) V1300WP V3600WP V5000WP R1000WP R1200WP H2500WP R900WP V13000WP TD1600P TD2000P TD3000P TD6000P TD9200P TD10000P TD12000P AS1600P AS2000P AS3000P AS6000P AS9200P AS10000P AS12000P AB15000
SIZE: See model.
SCOPE: Manufacturer recommended maximum operating temperature: Cold water use only. Hygienic Purposes: Non-metallic materials suitable for continuous use with cold water only.
MARKING Kingspan logo , address and technical information on data label.
MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.
BACKFLOW PROTECTION NOTES N/A.
ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements. Every storage cistern, except one supplying water to the primary circuit of a heating system, shall be fitted with a servicing valve on the outlet pipe (s). A servicing valve shall be installed on the supply to the fitting in a readily accessible location.

Extra Notes