



TITLE  
**PW375.INS.AG**

DRAWN BY  
C.MORRIS

DATE  
27/11/2017

CUSTOMER  
CUSTOMER

**NOTE:**  
All Tanks Direct tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.

ALL DIMENSIONS +/- 5mm  
UNLESS OTHERWISE STATED

DESCRIPTION:  
PW375 one piece cold water storage tank suitable for AG/AF Air gap

A4

ALL DIMENSIONS IN MM - DO NOT SCALE

| DATE       | VERSION | NOTES       |
|------------|---------|-------------|
| 05/10/2017 | A       | FIRST ISSUE |
|            |         |             |
|            |         |             |
|            |         |             |
|            |         |             |
|            |         |             |
|            |         |             |
|            |         |             |

| TANK SPECIFICATION : |                    |
|----------------------|--------------------|
| INTERNAL DIMENSIONS  | 500 x 500 x 1500mm |
| EXTERNAL DIMENSIONS  | 690 x 690 x 1509mm |
| NOM. CAPACITY        | 375Litres          |
| DRY WEIGHT           | 30 KG              |
| INSULATION THICKNESS | 25mm               |
| WRAS CERT. NUMBER    | 1310072            |
| MATERIAL             | GRP                |

SCALE:1:20

SHEET 1 OF 1