



<b>TITLE</b> PW9000.INS.AG		<b>NOTE:</b> All Tanks Direct tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.		<b>DESCRIPTION:</b> PW9000 one piece cold water storage tank suitable for AG/AF Air gap		<table border="1"> <thead> <tr> <th>DATE</th> <th>VERSION</th> <th>NOTES</th> </tr> </thead> <tbody> <tr> <td>06/11/2017</td> <td>A</td> <td>FIRST ISSUE</td> </tr> <tr> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>		DATE	VERSION	NOTES	06/11/2017	A	FIRST ISSUE																			<b>TANK SPECIFICATION :</b>			
DATE	VERSION	NOTES																																	
06/11/2017	A	FIRST ISSUE																																	
<b>DRAWN BY</b> C.MORRIS		<b>DATE</b> 27/11/2017		<b>INTERNAL DIMENSIONS</b> 3000 x 2000 x 1500mm		<b>EXTERNAL DIMENSIONS</b> 2192 x 2192 x 1593mm		<b>NOM. CAPACITY</b> 9000 Litres		<b>SCALE:1:30</b>																									
<b>CUSTOMER</b> CUSTOMER		ALL DIMENSIONS +/- 5mm UNLESS OTHERWISE STATED		A4		ALL DIMENSIONS IN MM - DO NOT SCALE		<b>DRY WEIGHT</b> 405 KG		<b>SHEET 1 OF 1</b>																									
<b>INSULATION THICKNESS</b> 25mm		<b>WRAS CERT. NUMBER</b> 1310072		<b>MATERIAL</b> GRP																															