



TITLE		<small>NOTE:</small> All Tanks Direct tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.
PW2000.INS.AB.4		
DRAWN BY	DATE	
C.MORRIS	27/11/2017	
CUSTOMER		
CUSTOMER		

DESCRIPTION:	
PW2000 one piece cold water storage tank c/w raised float valve housing to provide an AB Air gap	
A4	

ALL DIMENSIONS IN MM - DO NOT SCALE	
-------------------------------------	--

DATE	VERSION	NOTES
10/10/2017	A	FIRST ISSUE

TANK SPECIFICATION :	
INTERNAL DIMENSIONS	2000 x 1000 x 1000mm
EXTERNAL DIMENSIONS	2202 x 1202 x 1310mm
NOM. CAPACITY	2000 Litres
DRY WEIGHT	148 KG
INSULATION THICKNESS	25mm
WRAS CERT. NUMBER	1310072
MATERIAL	GRP

SCALE:1:25	SHEET 1 OF 1
------------	--------------