



TITLE
PW751.INS-2.AB.6

DRAWN BY C.MORRIS DATE 27/11/2017

CUSTOMER CUSTOMER

NOTE:
All Tanks Direct tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.

DESCRIPTION:
PW751-2 piece cold water storage tank c/w raised float valve housing to provide an AB Air gap

DATE	VERSION	NOTES
09/10/2017	A	FIRST ISSUE

TANK SPECIFICATION :

INTERNAL DIMENSIONS	1000 x 1000 x 750mm
EXTERNAL DIMENSIONS	1180 x 1180 x 1060mm
NOM. CAPACITY	750 Litres
DRY WEIGHT	49 KG
INSULATION THICKNESS	25mm
WRAS CERT. NUMBER	1310072
MATERIAL	GRP



SCALE:1:20 SHEET 1 OF 1

A4 ALL DIMENSIONS IN MM - DO NOT SCALE