



TITLE  
**PW.2x2x1.IFB**

DRAWN BY **C.MORRIS** DATE **03/04/2019**

CUSTOMER **CUSTOMER**

**NOTE:**  
Tanks Direct sectional tanks must be fully supported on a flat, level & continuous foundation which provides structural support to the tank when full to a maximum capacity. It is essential that the installer and/or user refers to the conditions of the installation document prior to the installation of the tank. Under no circumstances should any part of the tank structure be used to provide support to pipework and/or any ancillary items.

ALL DIMENSIONS +/- 5mm UNLESS OTHERWISE STATED

DESCRIPTION:  
**PW.2x2x1.IFB Sectional cold water storage tank c/w manway access**

A4

ALL DIMENSIONS IN MM - DO NOT SCALE

DATE	VERSION	NOTES
03/04/2019	A	FIRST ISSUE

**TANK SPECIFICATION :**

INTERNAL DIMENSIONS	2000 x 2000 x 1000mm high
EXTERNAL DIMENSIONS	2140 x 2140 x 1207mm high
NOM. CAPACITY	4,000 Litres
INSULATION THICKNESS	25mm
MATERIAL	Hot press moulded GRP



SCALE:1:40 SHEET 1 OF 1