



TITLE CU3.5000.AB	
DRAWN BY J. Ellison	DATE 20/01/2022
CUSTOMER CUSTOMER	

NOTE: All tanks must be fully supported on a flat level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.	A4
ALL DIMENSIONS +/- 5mm UNLESS OTHERWISE STATED	

DESCRIPTION: CU3.5000.AB Combination Unit c/w AB Air gap	ALL DIMENSIONS IN MM - DO NOT SCALE
--	-------------------------------------

DATE	VERSION	NOTES
22/12/2021	A	FIRST ISSUE

TANK SPECIFICATION :	
WET COMPARTMENT	2200 x 1800 x 1800mm
DRY COMPARTMENT	1200 x 1800 x 1800mm
EXTERNAL DIMENSIONS	3560 x 1960 x 1918mm
NOMINAL CAPACITY	7100 Litres
DRY WEIGHT	XXX KG
INSULATION THICKNESS	25mm
MATERIAL	GRP

	SCALE:1:45	SHEET 1 OF 1
--	------------	--------------